

DRAFT

Approved For Release 2001/08/07 : CIA-RDP78-06501A000300020012-3

25X1A5a1

ITEMS FOR

1. Diesel Electric Set - (Room 122)

a. Overall size of Diesel Electric Sets:

(1) 10 KW - 20"W X 58"L

(2) 15 KW - 27"W X 62"L

(3) 25 KW - 33"W X 72"L

(4) 50 KW - 33"W X 82"L

(5) 60KW  
(6) 75KW

33" X 85" L  
33" X 93" L

Must have total emergency load for sizing of Diesel Electric set before ordering Diesel Electric Set. Would like to have this information as soon as design permits so that specifics on Diesel Electric Set may be provided for finalizing layout and design of room.

b. Require Diesel Storage Tank. Presume local codes will permit a 275 gallon tank inside room. If so, provide for one. If not, will require an outside tank with a capacity of gallons.

c. Diesel Electric Set will be provided by occupant but installed by Construction Contractor.

d. It may be more practical depending on size of Diesel Electric Set radiator exhaust. No install larger double doors than shown for room, using one leaf as fixed for the radiator exhaust, the other leaf being for personnel access. This would provide a larger total opening for installing and future replacement of Diesel Electric Set. Furthermore, fixed leaf would only be used when installing or replacing Diesel Electric Set.